



U.S. Department of Justice

Federal Bureau of Prisons
Administrative Division

Field Acquisition Office

Grand Prairie, Texas 75051

August 2, 2018

ATTN: ALL BIDDERS

RE: Amendment Number 00002 (#2)
Solicitation 15B50818B00000004
FCC Forrest City, Arkansas
Replacement Generator (Low Facility)

Dear Bidders,

Enclosed is amendment number 00002 (#2), to the above referenced project. This amendment is issued to establish a new bid opening date, change the performance period and make changes to the drawings and specifications.

You **must** acknowledge receipt of this amendment (all amendments) by the method as described in item eleven of the Standard Form 30.

If you have any questions regarding this amendment, feel free to contact me at (972) 352-4641 or e-mail at dpatton@bop.gov

Sincerely,

Douglas V. Patton
Contracting Officer
Federal Bureau of Prisons
Field Acquisition Office
U.S. Armed Forces Reserve Complex
346 Marine Forces Drive
Grand Prairie, Texas 75051

Enclosure

cc: File
SCS, FCC Forrest City
COR, FCC Forrest City
Facility Manager, FCC Forrest City
Regional Facilities Administrator, SCRO

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE	
2. AMENDMENT/MODIFICATION NUMBER 00002		3. EFFECTIVE DATE 08/02/2018	4. REQUISITION/PURCHASE REQUISITION NUMBER N/A		5. PROJECT NUMBER (If applicable) 5C4G
6. ISSUED BY Federal Bureau of Prisons Field Acquisition Office U.S. Armed Forces Reserve Complex 346 Marine Forces Drive Grand Prairie, TX 75051		CODE 15BFA0 Douglas V. Patton (O) (972) 352-4641 (F) 972-352-4545 dpatton@bop.gov	7. ADMINISTERED BY (If other than Item 6) Federal Bureau of Prisons FCC Forrest City 1301 Dale Bumpers Forrest City, AR 72335		CODE 15B508
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, country, state and ZIP Code)				(X)	
				X	
				9A. AMENDMENT OF SOLICITATION NUMBER 15B50818B00000004	
				9B. DATED (SEE ITEM 11) 05/23/2018	
				10A. MODIFICATION OF CONTRACT/ORDER NUMBER	
				10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

The above referenced invitation for bid is amended to incorporate the following: see continuation page(s).

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Douglas Patton Contracting Officer	
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED 8/2/18	16B. UNITED STATES OF AMERICA By _____ (Signature of Contracting Officer)	16C. DATE SIGNED

Previous edition unusable

SF-30 Block 14 Description of Amendment (continuation)

1. Replace original design drawing E101 with revised drawing E101 (see attached)
2. Replace original design drawing E201 with revised drawing E201 (see attached)
3. Add "Specifications - Medium Prison Digital Master Control Upgrade" (see attached)
4. Add drawing E701 as a reference (see attached)
5. Add "Schematics and Diagrams - Medium Prison Switchgear" as a reference (see attached)

6. Change Note #5 on sheet ED101 to read as follows: "Existing main switchboard "MSB" to remain and be connected to the new paralleling gear. Prior to connection, the "MSB" shall be deenergized, tested, inspected, and cleaned (remove dust and contaminants from breakers and bus bar). Power disruptions shall be minimized as outlined on sheet E101."

7. Add the following requirement on sheet E101: "Existing Low Prison main switchboard "MSB" controls shall be replaced and upgraded, to include new PLCs and relays, and networked to the Low Prison system programmable controller attached to the Low paralleling gear "MSP". The Low Prison system programmable controller, with "MSB" feeder data/status, shall then be networked to the Medium Prison as indicated in the design drawings. Intent is to allow the Medium Prison staff to monitor status of the Low Prison generator as well as all breakers/feeders within the Low Prison main switchboard "MSB" and paralleling gear "MSP"."

8. Add the following requirement on sheet E102: "Existing Medium Prison main switchboard and paralleling gear digital master controls shall be replaced in accordance with the attached digital master control specifications. The contractor shall network Low Prison controls, as indicated above, into the Medium Prison digital master controller so that Low prison equipment can be monitored from a graphic display screen. The digital master controller within the Medium Prison shall provide supervisory control of Medium power equipment via a touchscreen interface mounted in the Operator's Office. The master control system for both prisons shall be from the same manufacturer."

9. On diagram 01, sheet E201, add the following note: "Rework/extend conduits as needed to connect new feeders "HV-DPF" to new double-ended 480V substation "DPF".

10. On sheet E001: Design and installation of a new fire alarm system is not a requirement of this contract.

11. At page 1, block 11 of the Standard Form 1442 and at page 18 of the solicitation, FAR clause 52.211-10, Commencement, Prosecution and Completion of Work, item (c), is changed to read 515 calendar days.

**12. A NEW BID OPENING DATE HAS BEEN ESTABLISHED FOR TUESDAY,
AUGUST 14, 2018 AT 1:00 P.M. CENTRAL STANDARD TIME. THE LOCATION
FOR THE BID OPENING HAS NOT CHANGED AND REMAINS THE SAME.**

(END OF AMENDMENT).

SF-30 Block 14 Description of Amendment (continuation) 15B50818B00000004/00002
PAGE 3 OF 3